

PUBLIC POOL INSPECTION FORM

Facility Name: _____

Address: _____

Pool Supervisory Person & Title: _____

Pool Approval Date: _____

Type of Pool

- | | |
|------------------------------------|--|
| <input type="checkbox"/> Swimming | <input type="checkbox"/> Indoor |
| <input type="checkbox"/> Wading | <input type="checkbox"/> Outdoor |
| <input type="checkbox"/> Whirlpool | |
| <input type="checkbox"/> Other | Diving Board |
| | <input type="checkbox"/> Yes <input type="checkbox"/> No |

Pool Volume: _____ gals

Disinfectant Used: () Chlorine () Bromine () Other

Disinfectant Residual: Pool Free: (min 0.8 Cl) Total: _____ pH: (7.2-7.8 range)

Spa Free: (min 1.0 Cl) Total: _____ pH: (7.2-7.8 range)

U=Unsatisfactory S = Satisfactory Yellow Items-Unsatisfactory requires immediate closure Bold Items-Connecticut Public Health Code Section 19-13-B33b

POOL	<u>S</u>	<u>U</u>	EQUIPMENT ROOM	<u>S</u>	<u>U</u>
1. Clarity of water (drains visible in deepest part)			19. Circulating Pump (size: HP)		
2. Drains and grates secure and intact			20. Inlet & Outlet Gauges		
3. Depth markers on each side of pool and 2 on a Spa "No Diving" markers 4" high and contrasting color			21. Filter (type: size: ft ²)		
4. Skimmers/Gutters (water level)			22. Flow Gauge (flow: gpm)		
5. Wading Pool min. 2 Drains Min 1 Depth Marker on pool rim on each side			23. Pool Turnover Rate* Spa Turnover Rate* () N/A		
6. Make-up water (air gap)			24. Automatic Disinfection		
7. Ladders/ Stairs secure			25. Backwash Line (air gap)		
8. Deck (condition/cleaning 0.5% chlorine)			26. Chemical Storage and Ventilation		
9. Safety Gear (12' crook, ring & attached 50' rope/100ft.)			27. Test Kit (DPD) Available & Current		
10. Lifeguard/Lifeguard Stand 4' high			28. Record Keeping/Log Books Completed		
11. Sign - "Warning No Lifeguard on Duty" with 4" lettering			29. Pool Drainage Provisions (air gap)		
12. First Aid Kit – 24-unit American Red Cross (see back)			<u>OTHER</u>		
13. Sign- "No diving is permitted off the deck into shallow areas of the pool"			30. Bathhouse and toilets clean (0.5% Cl)/ maintained / vented		
14. Sign-Pool Rules (A-D) in pool & dressing rooms (see back)			31. Whirlpool Temp. (< 104.1°F)		
15. Sign-Spa Caution Section (e) (4) (A-E) (see back)			32. Water in Showers 90-105°F		
16. Emergency Communications at entrance/telephones			33. Drinking Water Provided		
17. Telephone readily available in immediate pool area			34. Liquid soap provided in showers		
18. Fence-4' Outside, Gates/Doors self-closing/latching/ 2in to ground/ 2in between vertical posts/ latch 3.5ft high			35. Other:		

*Turnover rate(hr) = Pool Volume / flow rate / 60 min/hr

Pass Fail Re-inspection Date: _____

Inspector and Date: _____

Pool Operator and Date: _____

*Remarks and Corrective Actions on page 2

Remarks/Corrective Actions:

Signs for Pool Area and Bathrooms

- (A) All persons shall bathe with warm water and soap before entering the pool.
- (B) Any persons known or suspected of having a communicable disease shall not use the pool.
- (C) Spitting or blowing the nose in the pool is prohibited.
- (D) Running, boisterous or rough play (except supervised water sports) is prohibited.

First Aid Kit Example

- 3 Triple antibiotic ointment packs, 0.5g each
- 4 Antiseptic cleansing wipes (sting free)
- 1 Hydrocortisone pack
- 2 Hand sanitizer packs
- 2 chewable aspirin tablets
- 20 Plastic adhesive bandages
- 10 Plastic adhesive bandages, 1" x 3"
- 2 Elbow and knee plastic bandages, 2" x 4"
- 5 Junior plastic bandages, 3/8" x 1-1/2"
- 1 Knuckle fabric bandage
- 1 Fingertip fabric bandage
- 3 Patch bandages, 1-1/2" x 1-1/2"
- 1 Instant cold compress
- 1 Triangular sling/bandage
- 1 Trauma pad, 5" x 9"
- 4 Gauze dressing pads, 3" x 3"
- 2 Gauze dressing pads, 4" x 4"
- 1 First aid tape roll, 3/4" x 5 yds
- 1 Gauze roll bandage, 3"
- 1 CPR one-way valve face shield, latex-free
- 1 Thermometer, one time use
- 2 Latex-free exam-quality vinyl gloves
- Scissors, 1 pair
- Plastic tweezers, 1 pair
- 1 American Red Cross Emergency First Aid Guide
- 1 Zippered clear-pocket soft pack

Signs for Spas

- CAUTION**
- (A) Elderly persons and those suffering from heart disease, diabetes, high or low blood pressure should not enter the spa.
 - (B) Unsupervised use by children is prohibited.
 - (C) Do not use while under the influence of alcohol, anticoagulants, antihistamines, vasoconstrictors, vasodilators, stimulants, hypnotics, narcotics or tranquilizers.
 - (D) Do not use alone.
 - (E) Observe a reasonable time limit, (preferably not longer than 15 minutes) then shower, cool down and, if you wish, return for another brief stay. Long exposures may result in nausea, dizziness or fainting.

Requirements for Emergency Communications

- Section (b) (18)**
- Instructions regarding emergency calls shall be prominently posted. All pools shall have posted at their entrance:
- a. Directions to the nearest telephone and the nearest first aid unit and resuscitation equipment
 - b. The telephone numbers, in large print at least one-quarter inches high, of the nearest police and fire departments, emergency medical service provider, hospital and physicians on call in the immediate area
- *Additionally, these telephone numbers shall be posted at the nearest telephone.**